

Режимная ведомость по ПС 35/6 кВ ЗАПАДНАЯ - 1 за 21.06.2017 лист № 1

Часовые показания приборов

Наименование ПС	Наименование фидера		ед. изм.												
	У, кВ	Дисп. наимен		1	2	3	4	5	6	7	8	9	10	11	12
Западная-1	6	3-1-1	А	-	-	-	-	-	-	-	-	-	-	-	-
Западная-1	6	3-1-11	А	-	-	-	-	-	-	-	-	-	-	-	-
Западная-1	6	3-1-3	А	50	50	50	45	50	55	60	65	65	65	65	60
Западная-1	6	3-1-5	А	15	15	15	15	15	20	25	35	35	30	35	30
Западная-1	6	3-1-7	А	65	65	60	65	70	75	78	85	85	85	80	80
Западная-1	6	3-1-9	А	8	8	8	8	10	10	12	15	15	15	12	12
Западная-1	6	3-1-10	А	-	-	-	-	-	-	-	-	-	-	-	-
Западная-1	6	3-1-13	А	15	15	15	15	15	20	20	25	20	25	20	20
Западная-1	6	3-1-15	А	30	30	25	30	32	28	30	32	30	30	30	30
Западная-1	6	3-1-28	А	-	-	-	-	-	-	-	-	-	-	-	-
Западная-1	6	3-1-31	А	30	30	30	30	30	30	35	40	45	50	70	75
Западная-1	6	3-1-38	А	5	5	5	5	5	5	8	8	10	10	10	10
Западная-1	6	3-1-39	А	8	8	8	8	8	10	15	35	40	40	45	45
Западная-1	6	3-1-41	А	10	10	10	10	10	15	20	20	25	25	25	20
Западная-1	6	3-1-42	А	5	5	5	5	5	5	8	10	15	15	15	20
Западная-1	6	3-1-34	А	5	5	5	5	5	5	10	10	10	15	15	10
Западная-1	6	3-1-37	А	5	5	5	5	5	5	8	10	10	10	15	5
Западная-1	35	T-1	А	45	45	45	45	45	50	50	58	55	55	55	55
Западная-1	35	T-1	кВ	35	35	35	35	35	35	35	35	35	35	35	35
Западная-1	6	T-1	А	220	220	220	225	230	235	240	255	255	255	255	250
Западная-1	6	T-1	кВ	6,0	6,0	6,0	6,0	6,0	6,0	6,0	5,9	5,9	5,9	5,9	6,0
Западная-1	35	T-2	А	50	45	50	50	50	50	55	60	60	60	60	60
Западная-1	35	T-2	кВ	35	35	35	35	35	35	35	35	35	35	35	35
Западная-1	6	T-2	А	310	310	310	310	315	325	330	340	340	345	340	340
Западная-1	6	T-2	кВ	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	5,9	5,9	6,0	6,0

